

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085AQ0713

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	BERETTA Via Risorgimento, 13, I-23900 Lecco (LC)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	Condensing boiler (cascade) with fan-assisted burner, electrical ignition and ionisation flame supervising
Model <i>Modell</i>	POWER ...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: B16/02/2114/EU from 19.02.2016 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	16-0138-GWR

70028/04-A-JE

21.06.2016 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.




DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
...Plus Box 50	nominal heat output: 13,3...44,2 kW heat input (Hi): 13,5...45,0 kW	
...Plus Box 100	nominal heat output: 13,3...88,3 kW heat input (Hi): 13,5...89,9 kW	
...Plus 50 DEP; ...X 50 DEP; ...X 50 DEP R.S.I.	nominal heat output: 13,3...34,2 kW heat input (Hi): 13,5...34,8 kW	
...Plus 100 DEP	nominal heat output: 13,3...68,3 kW heat input (Hi): 13,5...69,6 kW	
...Plus Box 85 Sys; ...Plus LE 85 SYS	nominal heat output: 13,3...75,3 kW heat input (Hi): 13,5...76,7 kW	
...Plus Box 115 Hi; ...Plus Box 115 Hi Sys; ...LE 115 HI SYS	nominal heat output: 13,3...112,9 kW heat input (Hi): 13,5...115,0 kW	
...X 35 DEP; ...X 35 DEP R.S.I.	nominal heat output: 5,2...30,9 kW heat input (Hi): 5,2...31,5 kW	
...Plus 50; ...X 50; ...X 50 R.S.I.	nominal heat output: 13,3...44,2; 12,9...40,1 (Ls) kW heat input (Hi): 13,5...45,0; 13,1...40,8 (Ls) kW	
...Plus 100	nominal heat output: 13,3...88,3; 12,9...80,2 (Ls) kW heat input (Hi): 13,5...89,9; 13,1...81,6 (Ls) kW	
...Plus Box 150	nominal heat output: 13,3...132,5; 12,9...120,3 (Ls) kW heat input (Hi): 13,5...134,9; 13,1...122,4 (Ls) kW	
...Plus Box 200	nominal heat output: 13,3...176,6; 12,9...160,4 (Ls) kW heat input (Hi): 13,5...179,8; 13,1...163,2 (Ls) kW	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The above listed model was certified under the Product-Identnumber CE-0085AQ0713 according to the Gas Appliance Directive (2009/142/EC).